



Hill International

Brooklyn College Field Office
2920 Campus Road, Brooklyn, NY 11210
Tel. (929-234-2166; Fax (212) 244-3740
kellyadams@hillintl.com

JANUARY 27, 2014
Addendum No. 4
Performing Arts Center Theater Package
Project No.: BY600-006-05

This Addendum is for the purpose of conveying the below Documents and is hereby made part of said Bid to the same extent as though it were originally included therein. Contact: Kelly Adams; kellyadams@hillintl.com.

This Addendum No.4 with all attachments is available on the Hill bid website at the following link: <http://pdm.hillintl.com/cuny>; Bidders who are not able to obtain the Addendum and attachments via download from the website are to contact Kelly Adams at the above email address and may obtain a copy of the documents on CD ROM by coming to Hill's field office at 2920 Campus Road, Brooklyn, NY 11210 between the hours of 9 a.m. and 5 p.m.; see the Information for Bidders of the Bid Documents for additional information.

Addendum No. 4 is as follows:

A. IMPORTANT NOTICE: THE DATE FOR SUBMISSION OF BIDS REMAINS UNCHANGED AND IS THURSDAY, JANUARY 30, 2014 NO LATER THAN 2:00 P.M. at the place set forth in the Bid Documents. The bids will be opened at 2:30 p.m. on the same date in accordance with the Bid Documents.

B. Responses to Bidder Requests for Information

1. 5PB-062 Question.

What is the extent of fabric-wrapped acoustic panels (per Specification Section 097723) in Room 136 (Performance Hall) and as identified with Keynote 9.17 on Drawings A415 and A-416 and related details.

Answer: Delete all reference to fabric-wrapped acoustic panels in Performance Hall 136. In locations identified on A-415 and A-416 for fabric-wrapped acoustic panels, substitute three layers of painted MDF acoustic panels (keynote 6.2).

END OF ADDENDUM 4

Performing Arts Center Theater Package
Project No.: BY600-006-05

Acknowledgment of Receipt of Addendum No. 4.

The Bidder is responsible to indicate on the Bid Form that this Addendum has been received by the Bidder in preparing the submitted bid. Failure to do so will render your bid non-responsive.

This and all Addendum Acknowledgement forms are to be included in Envelope No. 1 of the Bid. Failure to include the Addendum Acknowledgement will render your bid non-responsive.

By signing the line below, I am acknowledging that all pages of Addendum #4 have been received, reviewed and understood, and will be incorporated into the bid price submitted.

NAME OF BIDDER:

Print Name

Signature

Date

Company Name
